

## EAGLE SERIES - FIRE ALARM SYSTEMS

### SUPERVISED OUTPUT MODULE

#### LE-SOM



#### DESCRIPTION

The Supervised Output Module (LE-SOM), has been designed to provide application flexibility and quick response to emergency conditions. Flexibility is provided by a wide range of operating modes, including supporting multi-zone operations, and/or functions, up to 16 different modulation patterns and multi-state programming. The operating parameters for the LE-SOM are maintained by the module and do not require individual communication with the control system during emergency conditions to operate. The control panel simply broadcasts system conditions on the Signaling Line Circuit (LE-SLC) and the LE-SOMs do the rest based upon the custom configuration. Each LE-SOM provides a Class B Individual Circuit rated for 2.0 Amp @ 30 VDC. Each SOM also requires a 24 Volt power source in addition to the LE-SLC. Provide software controlled LED indication: blinks green or red when polled, or can be latched on.

#### FEATURES

- Flexible application
  - Quick response to emergency conditions
  - Operation parameters are maintained by the module, and individual communication with the control system during emergency conditions is not required
  - Contacts are rated 2.0 Amps @ 30VDC
  - Programming is highly flexible providing 16 priority states plus zoning capability
- Program status:
- LED will flash red or green
  - Programmed device output is turned off, silenced, or programmed to modulate pattern

#### SPECIFICATIONS

Supply Voltage	(S-SC) 17-41 VDC
Auxiliary Supply Voltage	18-30 VDC
Average Current Consumption (on S-SC Line)	Normal 220 $\mu$ A Maximum 300 $\mu$ A
Current Consumption on Auxiliary Power Lines	Typical 150 $\mu$ A
Dimensions	4.2"W x 4.7"H x 1.4"D
Ambient Temperature	32°F (0°C) ~ 120°F (49°C)
Mounting	4" square electrical box
Maximum Output Current	2A@30VDC power limited
Relative Humidity	90% RH Non-condensing



## EAGLE SERIES - FIRE ALARM SYSTEMS

### SUPERVISED OUTPUT MODULE

#### LE-SOM



Backside of a LE-SOM

#### ENGINEERING SPECIFICATIONS

The contractor shall furnish and install where indicated on the plans, addressable Supervised Output Module (LE-SOM). The modules shall be UL listed and compatible with Lifeco FireNET fire alarm control panel. A bi-colored LED shall indicate device status.

The LE-SOM shall be supplied with a plastic cover and shall be suitable for mounting to a 4" square or double gang electrical back box. The LE-SOM shall provide a monitor LED that is visible from outside the cover plate.

#### WIRING DIAGRAM

